

Gary R. Robbins, AIA

ADDENDUM NUMBER 1

TODAY'S DATE: February 25, 2010
PROJECT NUMBER: RA Project # 0912P
PROJECT: Stokes County Early College
OWNER: Stokes County, 1014 Main Street, Danbury, NC 27016
ARCHITECT: Robbins Architecture, PA
TO BIDDERS:

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

CHANGES TO THE DRAWINGS:

Sheet C-1: Delete reference to HC Ramp and Steps on each side of the modular units. Ramps and steps to be provided by others.

Sheet C-2: Paving contractor to provide all conduit indicated under roadways and paving

ADDITION TO THE DRAWINGS:

Sheet C-1: Precast concrete bumper blocks shall be installed on each paved parking space indicated on plans without curb and gutter. Each bumper block shall be anchored with two #4 reinforcing bars minimum 24" below paving surface.

CLARIFICATIONS TO DRAWINGS:

Sheet C-3: Dumpster Pad Detail: Paving contractor will be responsible for the fence and gates around the dumpster pad.

CLARIFICATIONS TO THE SPECIFICATIONS:

Section 6: Asphalt Paving / Paragraph F: Surface Preparation / Item #4: Herbicide Treatment to be as specified and included in the bid

ADDITION TO THE SPECIFICATIONS:

AIA Document A201-2007 referred to in Section 00800: Item #1. Will include articles 1-15.

CHANGES TO THE SPECIFICATIONS:

Cover of Specifications: Owner: Delete South Stokes / Add: Stokes County

Section 6: Asphalt Paving / Paragraph J: Field Quality Control: Delete Item 1

Section 6: Asphalt Paving / Paragraph J: Field Quality Control: Add Item 1 to read: Testing of asphalt concrete mix and in-place hot-mixed asphalt courses for compliance with requirements for thickness and surface smoothness will be done by contractor's quality control procedures. Project engineer representative must be informed in advance as to the schedule for paving installation so as to allow field review of the work.

CLARIFICATIONS:

MWBE – Minority Business Participation forms must be included with the bid forms as per Section 00200: Article 19 / Item A

APPROVED EQUAL:

**Section 6: Asphalt Paving / Paragraph I: Traffic and Lane Marking / Item #2
Painting of arrows with an approved paint is an approved equal to the thermoplastic marking as specified**

Sheet C-1/ Typical Pavement with Curb and Gutter Detail: DOT State of Virginia mix is allowable with prior engineer approval and meeting standards of NCDOT mix. Mixture must be submitted and approved prior to the bid.

END OF ADDENDUM NUMBER 1