

**WASTEWATER SYSTEM
PERFORMANCE ANNUAL REPORT
2019**

I. General Information

Facility Name: Stokes County Wastewater Treatment Plant

Responsible Entity: Stokes County

Contact Person: Mark Delehant

Applicable Permit (s): NPDES Permit No. NC0082384

Description of collection system or process:

The system is a 0.100 million gallon per day (MGD) wastewater treatment plant consisting of a manual bar Screen, aerated flow equalization with dual pumps, dual aeration basin with three blowers, dual hopper bottom clarifiers, three module ultraviolet disinfection system, flow measurement and recording, and aerobic digestion.

II. Performance

Summary of system performance for calendar year 2019:

January 2019	Exceeded Fecal Coliform Weekly and Monthly Geometric Mean Limit.
February 2019	Compliant with effluent limits.
March 2019	Compliant with effluent limits.
April 2019	Exceeded Fecal Coliform Weekly and Monthly Geometric Mean Limit.
May 2019	Compliant with effluent limits.
June 2019	Compliant with effluent limits.
July 2019	Compliant with effluent limits.
August 2019	Compliant with effluent limits.
September 2019	Compliant with effluent limits.
October 2019	Compliant with effluent limits.
November 2019	Compliant with effluent limits.
December 2019	Compliant with effluent limits.

III. Notification

Annual notice is posted in the office of Stokes County Government and on the Stokes County web site at <http://www.co.stokes.nc.us/>

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge.

Mark Delehant
Responsible Person

Public Works Director
Title

Stokes County
Entity